

Electrical Inspectors, Inc.

300 East Meadow Avenue
East Meadow, NY 11554
Office: (516) 794-0400 (631) 396-7474
Fax: (516) 794-5854
Website: www.eiiny.com
Email: info@eiiny.com

Certificate Number: 2013-9202

Municipality: Hempstead, Town of

Inspector: 118

Issue Date: 11/19/2014

Mail To:

J.K. Electric Co., Inc.
James Kilcullen
374 Neptune Avenue
West Babylon NY 11704
License #: James Kilcullen 1820

Property Address:

Aqua Water NY
670 Seamans Neck Road
Seaford NY 11783

ELECTRICAL APPROVAL CERTIFICATE

Section: Block: Lot: Permit:

AREAS LISTED BELOW ARE APPROVED BY Inspection
AND FOUND TO BE IN COMPLIANCE WITH THE NATIONAL ELECTRIC CODE.

*No visual defects were found for the electrical inspection provided. No obvious unsatisfactory conditions
were found in the areas herein below only.*

Commercial Inspection Rough Approved 5/19/2014 Final Approved 11/17/2014

Entire Building.

Open Area: 7-Cubicle Motor Control Center, 1-280 kW Natural Gas Generator, 1-1200 Amp ATS, 1-75 kW Transformer, 1-45 kW Transformer, 1-125 Amp 30 Circuit Panel 120/208 16 Active, 1-225 Amp 42 Circuit Panel 120/208 25 Active, 1-25 Hp Pump, 2-1/2 Hp Exhaust Fans, 1-3 kW Heater, 4-Gas-fired Unit Heaters, 9-20 Amp 120 Volt Convenience Outlets, 3-400 Watt High Bays, 7-100 Watt Wall Packs, 8-2/40 Watt Fluorescent Fixtures.
Outside: 4-400 Watt Flood Lights, 3-LED Wall Packs.
New Service Underground 1 Meter 2000 Amps Three Phase 480/277 Main Circuit Breaker and CT Compartment.*

Richard M. Bivone
President

Philip F. Goehring, Jr.
Chief Electrical Inspector

Not valid unless signed by
an authorized EI agent

[Signature]